



ETA-Danmark A/S
Göteborg Plads 1
DK-2150 Nordhavn
Tel. +45 72 24 59 00
Internet www.etadanmark.dk

Authorised and notified according
to Article 29 of the Regulation (EU)
No 305/2011 of the European
Parliament and of the Council of 9
March 2011

MEMBER OF EOTA



European Technical Assessment ETA-22/0125 of 2022/03/15

I General Part

Technical Assessment Body issuing the ETA and designated according to Article 66 of the Regulation (EU) No 305/2011: ETA-Danmark A/S

Trade name of the construction product:

HENSOTHERM® 7 KS Gewebe 1000 E

Product family to which the above construction product belongs:

Fire stopping product – penetration seals.

Manufacturer:

Rudolf Hensel GmbH
Lauenburger Landstraße 11
DE-21039 Börnsen
Telephone: +49 40 72106210
www.rudolf-hensel.de

Manufacturing plant:

Rudolf Hensel GmbH
Plant 01

This European Technical Assessment contains:

7 pages including 1 annex which form an integral part of the document

This European Technical Assessment is issued in accordance with Regulation (EU) No 305/2011, based on:

European Assessment Document (EAD) No. 350454-00-1104: Fire Stopping and fire sealing products – Penetration seals

This version replaces:

-

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full (excepted the confidential Annex(es) referred to above). However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction must be identified as such.

II SPECIFIC PART OF THE EUROPEAN TECHNICAL ASSESSMENT

1 Technical description of the product.

The HENSOTHERM® 7 KS Gewebe 1000 E is an A2 glass filament woven fabric which is coated on one side with the intumescent HENSOTHERM® 7 KS fire-protection coating, the product is used to form a penetration seal to reinstate the fire resistance performance of a separating element (wall or floor) temporarily or permanently where they have been provided with apertures, which are penetrated by various services such like cable or pipe penetration.

2 Specification of the intended use(s) in accordance with the applicable European Assessment Document (hereinafter EAD)

The construction product HENSOTHERM® 7 KS Gewebe 1000 E is assessed on the basis of EAD 35054-00-1104, as a fire stopping product, penetration seal.

The construction product HENSOTHERM® 7 KS Gewebe 1000 E is intended for use as a component with a fire protection effect in building elements, assembled systems or constructions that are subject to requirements related to fire protection. Their reactive effect prevents heat transmission and fire spreading in the event of fire.

More information in table 3: “Performance of the product and references to the methods used for its assessment”.

The fire sealing products are to be installed according to the manufacturer’s installation manual.

The provisions made in this European Technical Assessment are based on an assumed intended working life of the HENSOTHERM® 7 KS Gewebe 1000 E of 10 years, provided the manufacturers conditions laid down in the manufacturers data sheet for the packaging, transport, storage, installation, use, maintenance and repair are met.

The indications given as to the working life of the construction product cannot be interpreted as a guarantee neither given by the product manufacturer or his representative nor by the Technical Assessment Body issuing an ETA based on the EAD No. 350454-00-1104 but are regarded only as means for expressing the expected economically reasonable working life of the product.

3 Performance of the product and references to the methods used for its assessment*

Characteristic	Assessment of characteristic									
3.2 Safety in case of fire (BWR2)										
Reaction to fire	The product is classified as Euroclass E in accordance with EN 13501-1 and Commission Delegated Regulation 2016/364									
Resistance to fire	The fire resistance is classified in accordance with EN 13501-2, more information in Annex 1									
3.3 Hygiene, health and the environment (BWR3)										
Air permeability (material property)	No performance assessed									
Water Permeability (material property)	No performance assessed									
Content, emission and/or release of dangerous substances*	<table><tr><td></td><td>After 3 days [mg/m³]</td><td>After 28 days [mg/m³]</td></tr><tr><td>SVOC</td><td>< 0,005</td><td>< 0,005</td></tr><tr><td>VOC</td><td>< 0,005</td><td>< 0,005</td></tr></table>		After 3 days [mg/m³]	After 28 days [mg/m³]	SVOC	< 0,005	< 0,005	VOC	< 0,005	< 0,005
	After 3 days [mg/m³]	After 28 days [mg/m³]								
SVOC	< 0,005	< 0,005								
VOC	< 0,005	< 0,005								
3.4 Safety in use (BWR4)										
Mechanical resistance and stability	No performance assessed									
Resistance to impact/movement	No performance assessed									
Adhesion	No performance assessed									
Durability	Use condition: X									
3.5 Protection against noise (BWR5)										
Airborne sound insulation	No performance assessed									
3.6 Energy Economy and heat retention (BWR6)										
Thermal properties	No performance assessed									
Water vapour permeability	No performance assessed									

See additional information in section 3.9 – 3.10.

*) In addition to the specific clauses relating to dangerous substances contained in this European technical Assessment, there may be other requirements applicable to the products falling within its scope (e.g., transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the Construction Products Regulation, these requirements need also to be complied with, when and where they apply.

3.9 Methods of verification

The characteristic values of the joint sealing system are based on the EAD 350454-00-1104.

3.10 General aspects related to the fitness for use of the product.

The verification of durability is part of testing the essential characteristics. HENSOTHERM® 7 KS Gewebe 1000 E may be used in end-use applications according to the provisions for use category X (intended for use in conditions exposed to weathering) without expecting significant changes of the characteristics relevant for fire protection. Products that meet the requirements for type X, meet the requirement for all other types.

Optionally the product was successfully tested under specific application conditions:

- Exposure to a constant temperature of 80 °C for 40 days.
- Exposure to solvents (tested with Butylacetat, Butanol, solvent naphtha and fuel)
- subsequent over-painting (tested with coatings on the basis of acryl dispersion, alkyd resin, polyurethan acryl and epoxide resin)
- Exposure to water immersion for 4 weeks
- Exposure to intimate contact to plastics (PVC,PE)

The characteristics “expansion ratio” and “expansion pressure” did not change essentially due to the exposure.

The European Technical Assessment is issued for the product based on agreed data/information, deposited with ETA-Danmark, which identifies the product that has been assessed and judged. Changes to the product or production process, which could result in this deposited data/information being incorrect, should be notified to ETA-Danmark before the changes are introduced. ETA-Danmark will decide if such changes affect the ETA and consequently the validity of the CE marking based on the ETA and if so whether further assessment or alterations to the ETA, shall be necessary.

HENSOTHERM® 7 KS Gewebe 1000 E is manufactured in accordance with the provisions of this European Technical Assessment using the manufacturing processes as identified in the inspection of the plant by the notified inspection body and laid down in the technical documentation.

4 Assessment and verification of constancy of performance (hereinafter AVCP) system applied, with reference to its legal base.

4.1 AVCP system

According to the decision 1999/454/EC of the European Commission, as amended, the system(s) of assessment and verification of constancy of performance is system 1 (see Annex V to Regulation (EU) No 305/2011).

5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD.

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited at ETA-Danmark prior to CE marking

Issued in Copenhagen on 2022-03-15 by



Thomas Bruun
Managing Director, ETA-Danmark

