

Attestation

Based on the evaluation of Test Report No. 50945-001 dated March 14th 2016 and 50945-002 dated February 17th 2016 the testing results of product

Hensotherm 490 KS

manufactured by

Rudolf Hensel GmbH
Lauenburger Landstr. 11
21039 Börnsen
DE

comply with the requirements of

- VOC product emissions acc. to California Department of Public Health (CDPH) Standard Method v1.1–2010 (California Specification 01350 (02/2010)) and
- VOC content ASTM D 2369 – 10 and South Coast Air Quality Management District (SCAQMD) Rule 1113

These criteria meet the requirements for low-emitting paint and coating materials in credit EQc2 of the LEEDv4 Rating System.

Cologne, 14th March 2016



Daniel Tigges, Dipl.-Holzwirt
(Project Manager)